

# ATTESTATION OF CONFORMITY



<b>Directive(s):</b>	2014/30/EU
<b>Attestation No.:</b>	DECE1803164
<b>Applicant / Holder:</b>	APLUS POWER CORP.
<b>Address:</b>	83-12, Kan-Tsu., Tzu-Tong, Yunlin 64742, Taiwan
<b>Trade Mark:</b>	
<b>Product / Test Item:</b>	Line interactive UPS
<b>Model / Type Reference:</b>	UPS-400C, UPS-500C, UPS-600C, UPS-700C, UPS-800C

The submitted sample(s) have been tested with the following standard(s) and found to be in compliance with the essential requirements of the Directive(s):

Standard(s)	
EN 55032: 2015	EN 55024: 2010+A1: 2015
EN 61000-3-2: 2014	IEC 61000-4-2 : 2008
EN 61000-3-3: 2013	IEC 61000-4-3 : 2006+A1:2007+A2:2010
	IEC 61000-4-4 : 2012
	IEC 61000-4-5 : 2014
	IEC 61000-4-6 : 2013
	IEC 61000-4-8 : 2009
	IEC 61000-4-11 : 2004

The referred test report(s) show that the product fulfills the essential requirements set out in the Directive(s). On this basis, together with the manufacturer's own documented production control, the manufacturer or his European authorized representative can in his EC Declaration of Conformity verify compliance with the Directive(s). The CE marking could be affixed only when all the relevant and effective EC Directives are complied with.



Miro Chueh  
EMC/RF B.U. Manager  
2018-04-18

Cerpess Technology Corporation

- Cerpess Technology Corporation Test Laboratory  
No.10, Ln. 2, Lianfu St., Luzhu Dist., Taoyuan City 33848, Taiwan
- Cerpess Technology (Suzhou) Co.,Ltd.  
No.66, Tangzhuang Rd., Suzhou Industrial Park, Jiangsu 215006, China